



| ITEM NO | NO. REQ'D | SIZE AND DESCRIPTION | MATERIAL SPEC'S |
|---------|-----------|-------------------------------------|-----------------------------------|
| 1 | 1 | MAIN SIZE X 2" REDUCER (WHEN REQ'D) | PVC SLIP JOINT |
| 2 | 1 | 2" - 90° ELBOW | PVC SLIP JOINT |
| 3 | 1 | 2" X SLIP & THREAD ADAPTOR | SCH. 80 PVC |
| 4 | 1 | 2" X REQ'D LENGTH RISER | SCH. 80 PVC |
| 5 | 2 | 2" - 90° SCRD. ELL | SCH. 80 PVC |
| 6 | 1 | 2" SCRD. CAP | SCH. 80 PVC |
| 7 | 1 | 2" SCRD. SWING CHECK VALVE | M & H NO. 59 |
| 8 | 1 | 2" RES. WEDGE GATE VLV. | MUELLER H-10203 |
| 9 | 1 | 2" X 10" NIPPLE | SCH. 80 PVC |
| 10 | 3 | 2" SHORT NIPPLES | SCH. 80 PVC |
| 11 | 1 | METER BOX | BROOK SERIES 66 OR APPROVED EQUAL |
| 12 | 1 | PRECAST SECTION | ASTM C-478 OR APPROVED EQUAL |
| 13 | 1 | WATER TIGHT RING & 32" COVER | PER CITY OF AUSTIN STANDARD |

NOTE:

FLUSHING ASSEMBLY SHALL NOT BE INSTALLED IN PAVEMENT.



TRAVIS COUNTY WATER CONTROL AND
IMPROVEMENT DISTRICT No. 17
STANDARD DETAILS

ADOPTED:

03/01/2016

PRESSURE MAIN FLUSHING
ASSEMBLY
(END OF LINE)

THE ARCHITECT/ENGINEER ASSUMES
RESPONSIBILITY FOR APPROPRIATE
USE OF THIS STANDARD.

DETAIL NO.

WW31