



NOTES:

1. VALVE EXTENSIONS ARE REQUIRED ON ALL VALVES THAT EXCEED 3' (0.9 m) DEEP FROM FINISHED GRADE. VALVE EXTENSIONS SHALL BE PLACED SUCH THAT THE EXTENSION NUT IS BETWEEN 18 AND 24" (457 AND 600 mm) FROM FINISHED GRADE.
2. VALVE, DUCTILE IRON PIPE AND STANDARD HYDRANT SYSTEM SHALL BE RESTRAINT JOINT CONTINUOUSLY TOGETHER.

	TRAVIS COUNTY WATER CONTROL AND IMPROVEMENT DISTRICT No. 17 STANDARD DETAILS	BLOW-OFF HYDRANT INSTALLATION DETAIL	
	ADOPTED: <p style="text-align: center;">06/15/2010</p>	THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR APPROPRIATE USE OF THIS STANDARD.	DETAIL NO. <p style="text-align: center;">W02</p>