



TRAVIS COUNTY WATER CONTROL & IMPROVEMENT DISTRICT 17

3812 ECK LANE • AUSTIN, TEXAS 78734
PHONE (512) 266-1111 • FAX (512) 266-2790

The Uniform Plumbing Code, 2009 edition, published by the International Association of Plumbing and Mechanical Officials (2009 Plumbing Code) is adopted including all appendices, except Appendices K, with deletions and amendments.

The following provision(s) of the 2009 Plumbing Code are deleted.

Section 807.4

WCID 17 Local Amendments to the Plumbing Code

The following provisions are local amendments to the 2009 Plumbing Code. Each provision in this section is a substitute for the identically numbered provision in the 2009 Plumbing Code or is an addition to the 2009 Plumbing Code.

Section 707.4

Exceptions:

- (5) A four (4) inch two-way cleanout fitting with a maximum 18 inch extension may be installed as a cleanout in a four (4) inch building sewer line.

Section 710.7.1 Fitting Allowance.

Schedule 40 PVC pressure couplings, pressure wyes and pressure 45° ells shall be allowed in the discharge line from an ejector pump or other mechanical devices used for drainage purposes.

Section 712.2

Exceptions:

- (1) When leaks are detected in the drainage and venting systems they shall be corrected, re-tested and inspected until work is found to be tight and conforms to this code.
- (2) Below slab drainage repairs and plumbing drainage piping above the first floor ceilings in residential buildings shall be allowed to be subjected to a 42 Inch Head Water Test above the floor level being tested in lieu of a 10 Foot Head Water Test.

Section 807.4 Domestic Dishwashing Drain.

Hoses shall be allowed to be looped to the highest point under the kitchen sink counter and secured to the cabinet or counter in lieu of a deck mounted air gap fitting.