

# TRAVIS COUNTY WATER CONTROL & IMPROVEMENT DISTRICT 17

3812 ECK LANE • AUSTIN, TEXAS 78734 PHONE (512) 266-1111 • FAX (512) 266-2790

The Uniform Plumbing Code, 2015 edition, published by the International Association of Plumbing and Mechanical Officials (2015 Plumbing Code) is adopted including all appendices, except Appendices F and H, with deletions and amendments.

## WCID 17 Local Amendments to the 2015 Plumbing Code

The following provisions are local amendments to the 2015 Plumbing Code. Each provision in this section is a substitute for the identically numbered provision in the 2015 Plumbing Code, a deletion or an addition to the 2015 Plumbing Code.

## **Not Adopted:**

The following provision(s) of the 2015 Plumbing Code is not adopted. Sections 911.0 through 911.3.1 Circuit Venting

#### **Additions:**

### Section 710.7.1 Fitting Allowance

Addition: Schedule 40 PVC pressure couplings, pressure wyes and pressure 45° ells shall be allowed in the discharge line from an ejector pump or other mechanical devices used for drainage purposes.

#### Section 807.4.1 Domestic Dishwashing Drain

Addition: Hoses shall be allowed to be looped to the highest point under the kitchen sink counter and secured to the cabinet or counter in lieu of a deck mounted air gap fitting.

#### **Exceptions:**

Section 707.4 Sanitary Drainage - Location

## Exception:

(5) A four (4) inch two-way cleanout fitting with a maximum 18 inch extension may be installed as a cleanout in a four (4) inch building sewer line.

# Section 712.2 Sanitary Drainage – Water Test

#### **Exceptions:**

- (1) When leaks are detected in the drainage and venting systems they shall be corrected, retested and inspected until work is found to be tight and conforms to this code.
- (2) Below slab drainage repairs and plumbing drainage piping above the first floor ceilings in residential buildings shall be allowed to be subjected to a 42 Inch Head Water Test above the floor level being tested in lieu of a 10 Foot Head Water Test.