



TRAVIS COUNTY WATER CONTROL AND IMPROVEMENT DISTRICT 17

3812 Eck Lane • Austin, Texas 78734
• Phone (512) 266-1111 • Fax (512) 266-2790

Pressure Regulating Valve Requirements

- PRVs will have an all brass body
- Have a thermal expansion by-pass and stainless steel strainer,
- Watts LFN55BM1-U or equivalent models are acceptable.