

TRAVIS COUNTY WATER CONTROL AND IMPROVEMENT DISTRICT NO. 17
2016 TEST RESULTS FOR LEAD AND COPPER

Site No.	Street	Lead Action Level =	Copper Maximum	MCL Violation
		15.0 ppb	Contaminant Level = 1.3 ppm	
		Lead Result ppb	Copper Result ppm	
LC4001	TRAIL OF THE WOODS	1.45	0.182	No
LCR003	GERONIMO	1.85	0.109	No
LCR004	TRAIL OF THE WOODS	1.05	0.231	No
LCR005	MEADOWLARK	1.34	0.183	No
LCR006	END OF TRAIL	3.97	0.347	No
LCR007	S FLAMINGO	5.70	0.341	No
LCR009	BRANDING IRON	0.655	0.510	No
LCR011	ARROYO	2.67	0.0687	No
LCR012	ECK LANE	4.23	0.156	No
LCR013	HUDSON BEND	0.824	0.0705	No
LCR014	TECK CIRCLE	2.82	0.156	No
LCR015	HUDSON BEND	1.11	0.156	No
LCR016	LONGHORN LANDING	0.909	0.173	No
LCR017	STRADER	0.482	0.326	No
LCR018	RITTENHOUSE SHORES	0.987	0.186	No
LCR019	ARROYO	1.97	0.136	No
LCR024	JOHN SIMPSON	0.656	0.285	No
LCR026	PARKER BEND	1.22	0.682	No
LCR027	CANYON GLEN	1.13	0.134	No
LCR028	MERLENE	1.33	0.299	No
LCR029	RIVERBEND	1.18	0.174	No
LCR030	GENERAL WILLIAMSON	1.62	0.0706	No
LCR032	PHEASANT	1.50	0.219	No
LCR034	COYOTE	4.06	0.260	No
LCR039	ECK LANE	1.84	0.564	No
LCR040	DEBBA	0.882	0.180	No
LCR046	MEADOWLARK	2.36	0.135	No
LCR049	FLAMINGO	0.949	0.273	No
LCR050	FLAMINGO	0.596	0.112	No
LCR058	PHEASANT	0.974	0.0849	No

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter.)

ppm (parts per million): One part substance per million parts water (or milligrams per liter.)

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water.