



NOTES:

1. ALL MANHOLES LOCATED IN THE ROADWAY SHALL BE INSTALLED FLUSH TO MATCH ROAD SURFACE. MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL BE 12 INCHES ABOVE GRADE.



TRAVIS COUNTY WATER CONTROL AND
IMPROVEMENT DISTRICT No. 17
STANDARD DETAILS

ADOPTED:

03/01/2016

MANHOLE BACKFILL REQUIREMENTS

THE ARCHITECT/ENGINEER ASSUMES
RESPONSIBILITY FOR APPROPRIATE
USE OF THIS STANDARD.

DETAIL NO.

WW10