



GH091

General Features

The model GH091 (Gatorgrinder) grinder pump station is a complete unit that includes: the grinder pump, check valve, fiberglass tank, controls, and alarm panel. Designed specifically for installation in warmer climates, the Gatorgrinder is an efficient, economic station for single dwelling service.

- Flow ratings and tank capacities will vary with each tank size; refer to the station drawings or more information
- · Standard outdoor heights range from 60 inches to 96 inches

The tank is supplied complete with discharge fitting installed, simplifying installation of the grinder pump and plumbing. The GH091 uses E/One's "hardwired," or "wired," pump model where a cable connects the motor controls to the level controls through watertight penetrations.





1 hp, 1,725 rpm, high torque, capacitor start, thermally protected, 120/240V, 60 Hz, 1 phase

Inlet Connections

4-inch inlet grommet standard for DWV pipe. Field penetration and installation of inlet grommet allow site plumbing flexibility.

Discharge Connections

Tank is equipped with a factory-installed discharge fitting. Tank discharge terminates in 1.25-inch NPT female thread. Field connection of pump discharge to tank bulkhead is easily accomplished using the supplied discharge assembly or other material required by local code.

Discharge

15 gpm at 0 psig (0.95 lps at 0 m)

11 gpm at 40 psig (0.69 lps at 28 m)


7.8 gpm at 80 psig (0.49 lps at 56 m)


Accessories

E/One recommends that the Uni-Lateral, E/One's own stainless steel check valve, be installed between the grinder pump station and the street main for added protection against backflow.

Alarm panels are available with a variety of options, from basic monitoring to advanced notice of service requirements.

The Remote Sentry is ideal for installations where the alarm panel may be hidden from view.






Patent Numbers: 5,752,315 5,562,254 5,439,180

NA0060P01 Rev C

GH091




NOTE:
BALLASTING IS REQUIRED TO PREVENT
TANK FROM FLOATING.
INSTALL CONCRETE ANCHOR PER ENGINEERS RECOMMENDATIONS


Gatorgrinder

DETAIL SHEET, GATORGRINDER STATION

GH091-60



TANK BASE DETAIL



TANK VOLUME, LESS PUMP & DISCHARGE = 15.2cu ft/113.5 gal


TANK VOLUME (INTERNAL) = 15.7 cu ft/117.5 gal TANK WEIGHT W/LID = 71 lbs

AD	GAE	06/27/07	Α	
DR BY	CHK'D	DATE	ISSUE	SCALE


Gatorgrinder

GATORGRINDER STATION 60°

GH091-72



TANK BASE DETAIL



TANK VOLUME, LESS PUMP & DISCHARGE = 18.3cu ft/136.7 gal


TANK VOLUME (INTERNAL) = 18.8 cu ft/140.7 gal TANK WEIGHT W/LID = 81 lbs

	AD		06/27/07	Α	
I	DR BY	CHK'D	DATE	ISSUE	SCALE


Gatorgrinder

GATORGRINDER STATION 72"

GH091-84



TANK BASE DETAIL




TANK VOLUME, LESS PUMP & DISCHARGE = 21.4cu ft/159.9 gal

TANK VOLUME (INTERNAL) = 21.9 cu ft/163.9 gal TANK WEIGHT W/LID = 90 lbs

AD		06/27/07	Α	
DR BY	CHK ' D	DATE	ISSUE	SCALE


Gatorgrinder

GATORGRINDER STATION 84"









The Gatorgrinder is a wellengineered system designed to provide low pressure sewer service to individual residences or buildings. Proper installation of this equipment will ensure years of trouble-free service.

PRODUCT DESCRIPTION

The Gatorgrinder station consists of a grinder pump, tank and pump alarm panel. The tank is a fiberglass basin complete with a gasketsealed, fiberglass lid. Sewage enters the Gatorgrinder tank through the 4" (standard) inlet pipe where it is ground into fine particles by the grinder pump. The in-line pumping mechanism discharges the ground sewage to a force main, gravity main or a remote treatment site. The pump is a semi-positive displacement type capable of developing discharge pressures up to 80 psig. Ample tank storage capacity in conjunction with integral level sensing controls provides for economic, ondemand, operation of the grinder pump.

ITEMS REQUIRED FOR INSTALLATION

Prior to beginning installation of the Gatorgrinder station, a thorough review of these installation instructions is recommended. This will likely eliminate problems with inconvenient piping and cable locations or due to unavailable materials or equipment. In addition to the components furnished with each Gatorgrinder station, the following items will be needed to support installation:

 Supply voltage in accordance with the voltage specified on the Gatorgrinder nameplate.

- Bedding material (Section 2)
 - Concrete ballast (Section 3)
- 4" inlet pipe (from residence or building sewer) (Section 5)
- 1-1/4" discharge pipe to force or gravity main (Section 6)
- Compactible backfill material (Section 9)

The following tools:

- 5" diameter hole saw
- 1-1/16" diameter hole saw
- Pipe thread sealant (suitable for PVC)
 - · Pipe wrenches
 - · Water pump pliers
 - Electric drill, 1/2" chuck
 - · Common hand tools

INSTALLATION STEPS

The following instructions will provide the necessary information to properly install the Gatorgrinder system.

All applicable OSHA procedures must be follower.

All applicable OSHA procedures must be followed during installation of this equipment.

1. Station Unpacking (Figure 1)

The Gatorgrinder alarm panel, grinder pump and tank are shipped to the job site separately. Inspect the tank (1) and ensure that it sustained no damage during shipment. Proper handling of the fiberglass tank will ensure




FIG. 1 - STATION COMPONENTS

reliable performance. Do not drop the fiberglass tank or roll it on its side. Only a non-marring sling should be used to lift the fiberglass tank.

Ensure that all lifting equipment is rated for the load being lifted. Verify that the discharge fitting (4) is installed on the tank. Remove the fiberglass tank lid (2) and verify that the lid gasket (3) is installed.

The balance of the factory provided components were delivered with the grinder pump unit. Inspect the shipping cartons for signs of any damage sustained during shipment.

If damage is suspected on any of the Gatorgrinder components, do not proceed with installation. Notify your distributor of any damage discovered.

Open the shipping cartons and verify that the grinder pump (5), pump stand (6),

discharge piping kit (7), supply cable (8), cable grip (9), inlet grommet (10) and alarm panel (11) are enclosed. Notify your E/One distributor about any missing components.

2. Site Excavation

Excavate a hole of sufficient depth and width to accommodate the tank, underground piping and required backfill material as well as providing adequate working space for plumbing and electrical connections. The base of the excavated hole should be level and prepared with proper bedding material, such as gravel, in accordance with the site engineer's requirements. The depth of the excavation must be sufficient to accommodate the bedding material and tank burial to approximately 1" below the upper flange surface. The size, shape and shoring requirements of the

excavation will be based on the soil conditions and should be in accordance with the site engineer's recommendation and safety requirements.

3. Tank Installation

(Figure 2)

Improper handling of the fiberglass tank may result in damage and, ultimately, failure of the station. Care should be taken during lifting and placement to prevent impacting or otherwise damaging the tank. A non-marring sling should be used when lifting the tank by the fiberglass surfaces. Ensure that lifting sling is rated for the load being lifted. Lifting chains or cables should never be placed in direct contact with the fiberglass tank surfaces.

Place the tank on the level bed of fill material in the excavated hole. Orient the installed discharge fitting, as required, to align it with the existing or proposed discharge




FIGURE 2 - TANK INSTALLATION

piping path. Determine and mark the 4" DWV inlet pipe location on the fiberglass tank wall. The inlet pipe location corresponds with the actual or projected point where the 4" building sewer line intersects the tank wall. The center of the inlet pipe must be a minimum of 30 inches from bottom of the tank. The slope of the inlet pipe (per national and local code requirements) must be accounted for when determining the inlet location.

The supply cable path and cord grip location should be considered when selecting the inlet location (Section 8 and Figure 4). If the site conditions require concrete tank ballast to prevent flotation, ensure that the volume of concrete used complies with the site engineer's recommendation. Concrete ballast, if required, should be cast in place around the tank in the excavation. Do not pour the concrete ballast

above the marked inlet pipe location. If the ballast must be poured above this level, proceed with installation of the inlet piping (Section 5) before pouring the concrete. The inlet pipe must be sleeved with an 8" tube prior to pouring. The tank should be filled with water, to a level above the specified ballast height to prevent shifting during the concrete pour.

Alternatively, precast concrete, around the tank bottom, may be used for ballast (Figure 2). Do not pour ballast above the intended inlet location. If this ballast method is used, lifting hooks must be anchored in the concrete to support subsequent handling of the tank. The lifting hooks must be adequate to support the combined weight of the tank and concrete ballast, and should be sized and installed in accordance with the site engineer's recommendation.




FIGURE 3 - INLET INSTALLATION

Place the ballasted tank in the excavated hole using the lifting hooks. Do not lift the tank by any of the fiberglass surfaces if precast ballast is utilized.

4. Vent Installation

The Gatorgrinder station is supplied with a 2" mushroom vent, to be installed in the station cover.

Locate the 3" hole in the station cover. A vent hole may be added to a station cover in the field using a 3" diameter hole saw. Consult the factory before installing a vent hole in an existing station cover.

Install the rubber grommet in the hole in the station. The flange on the grommet should sit flush with the station cover.

Apply soap to the end of the nipple on the vent assembly. Align the nipple on the vent assembly with the grommet in the station cover and press the vent assembly down into the grommet until the vent housing bottoms on the grommet.

5. Inlet Installation

(Figure 3)

The type, size and venting requirements of the inlet pipe must be in accordance with all national and local plumbing codes. The Gatorgrinder is a sewage handling pump and requires ventilation for proper and safe operation.

The Gatorgrinder is supplied with a standard grommet to accept a 4" DWV (4.5" outside diameter) sewer inlet pipe. The grommet is self-sealing and does not require the use of additional sealant or adhesives. Other grommet sizes are available upon request. Verify that the grommet supplied

with the Gatorgrinder will accommodate the selected inlet piping.

Using a 5" hole saw, drill through the fiberglass tank wall at the marked inlet location. Install the supplied inlet grommet in the 5" hole.

Place a mark on the inlet pipe 3 1/2" in from the end that will enter the fiberglass tank. A bevel should be ground or filed on the pipe end to aid in installation through the grommet. Clean the grommet and pipe surfaces to remove any debris. Apply a film of pipe soap or dish soap to the outside surface of the inlet pipe end and the inside of the grommet. Insert the pipe end into the grommet and push the inlet pipe into the fiberglass tank until the 3 1/2" mark lines up with the grommet outside edge.

Inspect the grommet flange on the outside of the tank. The flange should be flush against the tank wall and completely visible when the pipe and grommet are installed properly.

6. Tank Discharge Piping Connection

Connect the tank discharge piping to the threaded tank fitting. The 1 1/4" NPT female thread on the discharge fitting will accommodate a variety of pipe materials and fittings. The discharge fitting is made of reinforced Nylon and the threads may be damaged if overtightened. Use a suitable threaded adapter and thread sealant to connect the discharge piping to the tank fitting. Typically, 1/2 to 1 1/2 turns beyond hand tight will produce a leak proof seal.

Discharge piping must be selected in accordance with local and national plumbing codes. If allowable, the use of 1 1/4, Schedule 40, Type 1, PVC pipe or SDR 11 polyethylene pipe is recommended. If polyethylene discharge piping is used, compression type fittings that provide a smooth inner passage should be utilized.

E/One requires that an E/One




FIGURE 4 - SUPPLY CABLE INSTALLATION

Uni-Lateral assembly (E/One part number NB0184PXX or NC0193GXX) or E/One Redundant Check Valve (E/One part number PC0051GXX) be installed in the pipe lateral outside the home between the pump discharge and the street main on all installations. Never use a ball-type valve as a check valve. E/One recommends the valve be installed as close to the public right-of-way as possible. Check local codes for applicable requirements.

7. Alarm Panel Mounting

Before proceeding, verify that the supply voltage is the same as the motor voltage shown on the grinder pump nameplate. Determine the location of the Gatorgrinder alarm panel.

The alarm panel may be mounted on a pole or directly on an outdoor wall surface. The mounting location selected must be visible from the Gatorgrinder station location and provide general visibility to the occupants of the building.

To mount the alarm panel, remove the panel front cover and secure to the wall or pole using standard #10 or #12 screws through the two mounting holes located on the back panel.

8. Supply Cable Installation (Figures 4 & 5)

A 32' supply cable and cord grip are provided with the Gatorgrinder station for electrical connection between the station and the alarm panel. All electrical wiring must be in accordance with local codes. A dedicated 30 amp breaker is required before all simplex alarm panels.

The supply cable is rated under the National Electric

Code (NEC) for direct burial as long as a minimum of 24" of ground cover is maintained. Those portions of the cable with less than 24" of cover must be housed in a suitable protective conduit.

The supply cable terminates in a convenient, electrical quick-disconnect (EQD) plug to support future servicing of the grinder pump. The supply cable cord grip provides a leak tight seal around the power cable as it enters the tank and will prevent movement of the supply cable during burial and subsequent ground settlement. The cord grip should be installed in a position on the tank that will provide convenient, direct routing of the supply cable to the alarm panel. The supply cable cord grip should be installed 25" below the top of the tank (see Figure 4).

Exception: On 48" tall tanks the cord grip should penetrate the tank 18" below the top of the tank; the portion of the cable with less then 24" of soil cover shall be installed in suitable protective conduit.

Locate and mark the location of the cord grip on the fiberglass tank wall. Using a 1 1/16" hole saw, drill through the tank wall at this location. Install the cord grip and O-ring seal as shown. Tighten the cord grip locknut until snug.

Loosen the cord nut and slide the supply cable free end through the cord grip (Figure 4). Continue to slide the entire cable length through the cord grip until the metal cable stop rests against the cord grip face. Tighten the cord nut until snug. Failure to tighten the cord

nut will result in groundwater entering the station.

Use care when installing and burying the supply cable. If the cable is cut or otherwise damaged it may result in a pump malfunction. Run the supply cable underground. ensuring 24", minimum, of soil coverage, to the alarm panel location. Leave a 6" to 12" loop of supply cable near the station and the alarm panel to accommodate settlement of the soil. A protective conduit must be utilized where 24" of soil cover cannot be maintained (Figure 5).

9. Tank Backfill

Proper backfill is essential to the long-term reliability of the Gatorgrinder station. The choice of backfill material is dependent upon the local soil and groundwater conditions and must be in accordance with the site engineer's recommendation. Heavy, noncompactible clays and silts are not acceptable backfill for the Gatorgrinder tank or any other underground structure such as the inlet or discharge piping.

Backfill should be placed and compacted in 12" lifts. Special




FIG. 5 - TYPICAL STATION INSTALLATION




FIGURE 6 - PUMP STAND INSTALLATION

care should be taken when placing backfill around inlet and discharge piping to ensure support and compaction. Do not strike the inlet pipe, discharge pipe or electrical connection with the compaction equipment during backfill.

The finished grade should be 1" below the upper flange on the fiberglass tank. The finished grade should be sloped down from the station to prevent water from pooling around the tank.

10. Grinder Pump Stand Assembly

Temporarily rest the grinder pump on its side. Using a block of wood or similar object, prop up the lower pump end to allow installation of the pump stand. Align the two legs of each pump stand half with two of the holes in the pump lower end. Push the stand legs into the pump lower end. Using a mallet, ensure that the stand legs bottom into the mounting holes. Repeat for the other stand half. Turn the pump upright on the installed stand.

11. Grinder Pump Installation

Lower the pump into the tank. Position the pump so the pump's discharge is on

the opposite side of the pump relative to the discharge in the tank. Position the pump in the center of the tank. Rotate to coil the discharge hose and slide the adapter on the discharge hose into the receiver in the tank wall. Push the white slider down to open the discharge valve.

Hang power cable, breather tubing with Equalizer, and lifting rope to prevent them from laying in sewage. Keep between 18 inches and 24 inches of power supply cable in tank. The Equalizer should be hung as high as possible in the tank.

12. Electrical Connections

The Gatorgrinder alarm panel contains a circuit breaker pair to protect the pump motor and a separate circuit breaker to control the alarm circuit. The station supply cable and power supply cable (from the building service) must be run into the panel and appropriately connected. All panel wiring should be completed by a qualified electrician and be in compliance with national and local electrical codes. Conduit should be provided, where required by code,

and adequate strain relief used on cable and/or conduit entry points. The appropriate wiring connections for the Gatorgrinder are shown in Figures 7. A dedicated 30 amp breaker is required before all simplex alarm panels.

13. Start-Up Test Procedure

When the system is completely installed, the station should be checked to ensure proper installation and reliable performance.

SYSTEM INSPECTION

Perform the following visual inspections:

- Proper burial depth the tank should have been buried to a level 1" below the fiberglass cover flange.
- Proper grading the surrounding soil should be graded down, away from the station.
- Station supply cable the station supply cable must not be exposed outside of the station. Suitable conduit must be used where proper burial depth (24") cannot be maintained.
- Alarm panel ensure that the alarm panel is properly mounted and free of any damage. Verify that the alarm panel has been wired properly in accordance with the wiring instructions in this manual.

ELECTRICAL TESTS

The following electrical tests are **recommended** prior to operating the grinder pump station. These tests require the use of appropriate electrical test equipment and should only be performed by qualified personnel trained in the safe operation of this equipment and

electrical system servicing.

- 1. Ensure that the electrical power supplying the alarm panel is "OFF."
- 2. Ensure that the grinder pump (double) and alarm (single) circuit breakers in the alarm panel are in the "OFF" position.
- 3. Using a test (ohm) meter, set at a 2 meg ohm setting, measure the resistance between the colored wire pairs shown in Table 1. Resistance readings are to be taken in the alarm panel on the colored leads supplying the pump station (supply cable). Resistance readings other than those shown in Table 1

TABLE 1

COLOR 1 COLOR 2 NORMAL READING

GRN/YEL RED GRN/YEL BROWN GRN/YEL BLACK

: = Infinity or open circuit

may indicate a problem with either the supply cable or the grinder pump. If the measured readings are not as indicated in Table 1, do not proceed with station start-up; contact your local E/One distributor.

- 4. Turn "ON" the power to the alarm panel from the building service panel.
- 5. Using a test (volt) meter, verify that the incoming panel voltage is within 10% of the pump nameplate voltage (for 240V pump, voltage at panel must be 216V to 264V). If the voltage is outside of this range, do not continue with station start-up. The voltage problem must be corrected prior to proceeding.


START-UP TEST

When the system is complete and ready for use, the following steps should be taken to verify proper installation and operation:

- a) Make sure that the discharge shutoff valve is fully open. This valve must not be closed when the pump is operating. In some installations there may be a valve, or valves, at the street main that must also be open.
- b) Turn on the alarm power circuit breaker. If a Protect Plus panel is used, "Failed WM Comm" will be indicated.
- c) Fill tank with water until the alarm turns on. Shut off water.
- d) Turn ON pump power circuit breaker; the pump should turn on immediately. Within one minute the alarm will turn off. Within three minutes the pump will turn off.

If a Protect panel is used, the Trouble LED may come on. If a Protect Plus panel is used, Trouble/Brown Out may be indicated.

e) If using a Protect panel, turn the pump and alarm breakers off and back on to



clear and reset the panel. On Protect Plus panels, perform a "cold start" to clear and reset the panel (any user setting that were previously chosen will not be reset).

OPERATIONAL ELECTRICAL TEST

The following electrical test is **recommended** in conjunction with the Start-Up Test of the grinder pump station. This test requires the use of appropriate electrical test equipment and should only be performed by qualified personnel trained in the safe operation of this equipment and electrical system servicing.

Make sure that the discharge shutoff valve is fully open. This valve must not be closed when the pump is operating. In some installations there may be a valve, or valves, at the street main that must also be open.

(Ignore all Trouble indications, LEDs and/or messages until the panel is reset at the end of this procedure.)

- 1. The current to the grinder pump should be measured in the alarm panel, at the white wire supplying the pump station (supply cable).
- 2. Using an ammeter, measure the current in the white wire while the pump is operating.

- 3. The current should be between 5 amps and 8 amps.
- 4. Higher amperage indicates higher discharge pressure.

Measured current in excess of 8 amps could indicate a blocked or closed discharge line. Correct any blockage problems and confirm that the current is within the acceptable range. If the current remains outside of the acceptable range, and no discharge blockage is detected, contact your local Gatorgrinder or qualified service representative.

5. Clear/Reset the alarm panel:

Sentry and T260 panels: Reset is not required.

Protect Panel: Turn pump and alarm breakers off and back on simultaneously.

Protect Plus Panels: Perform a "cold start" from the Initialize System menu. Any user setting that were previously chosen will not be reset.

If the grinder pump fails to perform as indicated, review the start-up procedure again and verify that all wiring connections are correct in accordance with these instructions. If the grinder pump still fails to perform as indicated, contact your local E/One distributor.