



TRAVIS COUNTY
WATER CONTROL AND IMPROVEMENT DISTRICT NO.17
3812 ECK LANE • AUSTIN, TEXAS 78734
PHONE (512) 266-1111 • FAX (512) 266-2790

Pressure Regulating Valve Requirements

- PRVs will have an all brass body
- Have a thermal expansion by-pass and stainless steel strainer,
- Watts LFN55BM1-U or equivalent models are acceptable.