


NOTES:

1. ALL MATERIALS SHALL BE LEAD FREE IN ACCORDANCE WITH THE SAFE DRINKING WATER ACT.
2. DEPENDING ON PRESSURE, IRRIGATOR SHALL DETERMINE LOCATION OF INSTALLATION EITHER BEFORE OR AFTER PRV.
3. NO PVC HIGHER THEN 21" ABOVE FINISH GRADE.

	TRAVIS COUNTY WATER CONTROL AND IMPROVEMENT DISTRICT No. 17 STANDARD DETAILS	RPZ INSTALLATION	
	ADOPTED: <p style="text-align: center;">03/01/2016</p>	THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR APPROPRIATE USE OF THIS STANDARD.	DETAIL NO. <p style="font-size: 1.2em;">W11</p>